

Public Notice

Important Information about Your Drinking Water

The Warm Springs water system is experiencing taste and odor issues in the drinking water

As our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Our activated carbon feed went down over the weekend and we were not able to feed the chemical that removes the taste and odor from the drinking water

What is being done?

Currently we are feeding powder activated carbon into the drinking water to remove any taste and odor also we are SHOCK TREATING the reservoirs with heavy doses of chlorine to neutralize the taste and odor. This will take a few days to move through the system and you may experience a heavy bleach smell in your drinking water.

Health Effects

Although, the water has a pond water smell, the water is safe to drink and shower with. We test the drinking water every 2 hours daily and we ship samples weekly for any bacteria and microbial contaminants to a water quality testing laboratory for verification that the water meets drinking water quality standards

If you have specific health concerns, consult your doctor.

For more information, please call: Roy Spino, Water/Wastewater Engineer at (541)553-3246

Water treatment plant operators at (541)553-1472

This notice is being sent to you by the Warm Springs water system.

Water System ID# 104101247

Date distributed: 06//17